Appendix 11

Services Plan and Molesworth Drive Roading Upgrade Plans / Wastewater

Kylie McLaughlin-Brown

From:

Robin Johnson < RJohnson@TRILITY.com.au>

Sent:

Thursday, 17 December 2015 2:41 p.m.

To:

Kylie McLaughlin-Brown Terry Roche; Simon Smith

Cc: Subject:

RE: capacity confirmation

Follow Up Flag:

Follow up

Flag Status:

Flagged

Kylie

I can confirm that there are sewer mains on both the Molesworth Drive and Estuary Drive boundaries of the site. There are no connection stubs shown on the plans but connections can be made to either line as appropriate.

It is outside our scope to comment on trade waste discharges other than to draw your attention to the provisions in KDC bylaws.

Robin

Robin Johnson Technical Support



leading the way in water utility solutions

TRILITY Pty Ltd

Mangawhai Community Wastewater Scheme Thelma Road South P O Box 220 Mangawhai 0540

+64 9 431 5946 M: +64 212 740 493

E: rjohnson@trility.com.au W: www.trility.com.au

Integrity Progressive Commitment

Consider the environment. Please don't print this e-mail unless you really need to.

TRILITY Group acknowledges and respects the privacy of individuals. The information above is intended for the addressee named and may contain confidential information.

If you are not the intended recipient, please delete it and notify the sender.

From: Kylie McLaughlin-Brown <kylie@dream-inc.co.nz>

Mangawhai Waste Water Treatment Plant <wwtp.mangawhai@pentair.com>

Date: 15/12/2015 12:45 PM
Subject: RE: capacity confirmation

Hi Robyn,







