Wastewater Strategy Workshop 22 May 2020



Introductions

wsp

Presentation - Who you are and role

- Louise Miller CEO
- Jim Septhon General Manager
- Donnick Mugutso Waters and Waste Manager
- Matthew Smith Planning and Design Engineer
- Brian Armstrong Operations Engineer Water Services
 Mark Bell Senior Infrastructure Projects Engineer
- Terry Roche Plant Operator
- Andrew Springer Technical Principal Wastewater Treatment Engineer
- Larey-Marie Mulder Senior Water and Wastewater Engineer
- Eros Foschieri Work Group Manager 3 Waters

Objective

- 1. Engage on the future of the Scheme.
- 2. Enable all to be aware of the history, the impact of growth and the timescales.
- 3. Raise awareness
- 4. Identify the key steps for delivery
- 5. Agree an outline strategy (roadmap)



Long Term Vision

۷SD





Mangawhai will grow well. While we grow, we shall care for nature, encourage a slow pace and active lifestyle, and retain the coastal character and history.

Strategic Response

| 1. | nature | protect and enhance biodiversity links, waterways, and the coastal area. | |
|----|------------------|--|--|
| 2 | iwi and heritage | celebrate Māori culture and make local history visible. | |
| 3 | three waters | provide efficient, clean infrastructure that will serve the community well into the future. | |
| 4 | living | direct growth outcomes which support community needs and housing choices. | |
| 5 | community | strengthen, enable and connect the local community through facilities and programmes. | |
| 6 | employment | support the local economy, and attract more visitors, entrepreneurs, and employment uses. | |
| 7 | transport | improve safe walking and cycling options, and manage vehicular traffic. | |

Growth Estimate of 15,222 people by 2043 (approx. 6000 connections)

Long Term Vision

۷SD

Three waters

Existing situation

- A 10-20 year upgrade for additional 7-10,000 population is under investigation
- Wastewater capacity for 1,000 more properties (6-7 years).
- The current zoning already provides for more than 1,000 properties
- There is a shortfall even without the provision of additional growth land.
- Water supply is limited and mainly via rain tanks.



- Current Permanent Population about 5000
- Increased 60% between 2013 and 2018
- Medium projection increase of 10,191 by 2043
- = Current Mangawhai X 3 + Commercial

Long Term Vision

****\$P

Wastewater Recommendations

- Progress waste water strategy, including considering options for:
- Disposal.
- Alternative funding.
- Re-use of treated waste water (irrigation of parks, firefighting etc.)
- Latest technological advances.



commute (%)



Water supply

Recommendation

 Undertake an ongoing review of ground water conditions as population and household numbers increase in Mangawhai.





Mangawhai Community Wastewater Scheme

Long Term Vision

۷SD

NOTE:

- Wastewater currently 300 l/house/d Tank Water (including infiltration)
- Future Wastewater, 450 l/house/d- Network Supply (including infiltration)

History of the CWWTP



۱۱SD

Mangawhai Heads

Thelma Rd CWWTP

Mangawhai

Irrigation Site

wsp

Built by Water Infrastructure Group Operational in 2009.

- Sized for Max 70 l/s
- Aeration sized for 5 years only.
- Tank expected big enough for 20 years

Budget Exceeded Community Expectations.

Actual PlantSewage is strongerPopulation
Water SourceLow Water usage300 I/connection per day off peak
600 I/connection per day peakExpected200 I/person/day, so about 500
I/connection off peak.

Storm Peak

> 70 l/s at Pump Station.

Upgrades

2018 Capacity Assessment + Farm Studies

2019 Upgrade Aeration to meet 2028 population Irrigation extended to 65 ha. Max usable land now in use.

Mangawhai Community Wastewater Scheme

History of the CWWTP

History of the CWWTP

vsp



Disposal Field

- 135 ha land
- 170,000 m³ Storage Pond
- 65.5 ha of irrigation

Issues

- No more usable land all in use that can be
- Odour
- Rising Main capacity
- Soil Condition

Irrigation Upgrades

32 ha

47 ha

2009

2012

2013

2016?

Mangawhai Community Wastewater Scheme

History of the CWWTP

۷SD

2019 65.5 ha

25 ha original at 350 mm/yr

Consent to deficit irrigation 500 mm/yr

Full Capacity reached before 3000 connections

Wet years may exceed capacity before this point.

Wastewater Network

****\$P



Wastewater Network



Network Growth

Residential growth areas

| Zone reference | Min lot size (ha) | |
|---|-------------------|--|
| Large residential lots | 0.4 - 0.8 | |
| Lifestyle lot | 0.8 - 2.0 | |
| Lifestyle lot with opportunity for equestrian | 2.0 - 4.0 | |
| Moderate rural character | Avoid | |
| High rural character | Avoid | |







Wastewater Network Currently serves 2000 connections Including Campgrounds, Shops, light industry, museums, cafes, bars, houses and public toilets.

Mixture of gravity and pumps systems.

Has grinder pumps and low pressure system to reuse some areas of gravity line (not best practice) for 426 connections

| Pump station name | Pump station ID | Design flow rate (l/s) | Design head (m) |
|-------------------|-----------------|---------------------------|-----------------|
| Lincoln | A | 8 | 19.8 |
| Cheviot | В | 9.5 | 18.6 |
| Sea Breeze | С | 11.9 | 3.1 |
| Heather | E | 9.5 | 8.9 |
| Fagan | F | 43.9 | 34.4 |
| Alamar | G | 39.2 | 18.5 |
| Pearl | Н | 9.5 | 27.6 |
| Wintle | J | 9.5 | 10.5 |
| Molesworth | VA | 21.4 | 24.0 |
| Thelma | Outfall | 70 | 10.4 |
| Jack Boyd | К | 27 | 39.0 |

Main Pump Stations from Trility 2016

Growth

٧SD

- Current System suitable for max 3000 connections.
- Upgrade is essential if Growth to occur with increase in
 - Network
 - Treatment Capacity
 - Disposal Route

Growth Timeline **at 70 connections** per year



- CWWTP will Reach Current Capacity in 2028/29
- 3000 connections by 2032
- Disposal Field Capacity exceeded by 2032

Growth Timeline at 70 connections per year





Growth Timeline at **70 connections** per year

wsp

- By 2028/2029 the CWWTP will struggle to meet the consent limits, specifically Nitrogen Removal as the plant becomes overloaded in Summer.
- By 2032 additional treatment capacity will be required as the plant will be hydraulically limited at about 3,000 connections.
 - Treated water pumps and rising main to Farm will be at hydraulic capacity
- By 2032 the disposal field will have reached capacity, additional disposal option will be required.

Growth Timeline at **100 connections** per year

wsp



- CWWTP will reach its current capacity in 2026
 - 3000 connections by 2028
- Disposal Field Capacity Exceeded by 2032

Growth Timeline at 100 connections per year



Growth Timeline at 100 connections per year

۷SD

- By 2026 the CWWTP will struggle to meet the consent limits, specifically on Nitrogen Removal as the plant becomes overloaded in Summer.
- By 2028 additional treatment capacity will be required as the plant will be hydraulically limited at about 3,000 connections.
 - Treated water pumps and rising mains will be at hydraulic capacity
- By 2028 the disposal field will have reached capacity, additional disposal option will be required.

Questions?

vsp

Questions so far ?

KDC Feedback

۱۱SD

Areas To Consider

- Feedback from Consultation
- Community Expectations
- Vision on Community Engagement
- Social, Cultural Iwi and Environmental Values
- Planning context LTP, Annual Plan, Expected delivery timescale
- Where and when Will growth Occur
- What level of commercial Growth
- Reuse for irrigation
- Environmental Sustainability, Carbon Footprint
 and renewables
- Climate Change Sea level and Climate
- Tsunami and Seismic risks
- Latest Technology

What is Required to Meet Growth



Wastewater Treatment

Option Considerations

Disposal to

- Land Estuary
- Ocean
- Reuse

Irrigation

Firefighting

Technology

Technology options available will largely be driven by the disposal and/or reuse option.

Land Disposal

****\$P

Land Treatment

- Additional land (Farm) will be required as current disposal field will reach capacity
- At irrigation rate 5,000 m³/hectare/year:
 - 62 hectares required for 5,000 connections
 - 123 hectares required for 7,000 connections
 - 215 hectares required for 10,000 connections
- Above assumes only 60% of farm suitable for irrigation
- New Consent Required.
- Plus upgrade to Treatment Works
- New Rising Main and Pumps

Land Disposal

wsp

Treatment Technology

- Same technology as current CWWTP
- Cyclical Activated Sludge System (CASS)
- Meets consented water quality requirements
- Suited to seasonal variation
- Modular approach to increase the capacity
- Upgrade can be future proofed for 7,000 connections
- Upgrade always requires equal amount of reactors (2, 4 then 6)

Land Disposal

۷SD

Limitations

- Area Required about 1.3 1.5 x Application Area
- Land Purchase
- Neighbours
- New Rising Main
- Capital Cost
- Benefits
 - Iwi Acceptable

Land Disposal Treatment Upgrade

۷SD



5000 Connections

7000 Connections



Sea Outfall Discharge

Sea Outfall

- Existing disposal field remains available and run at capacity
- New consent required for discharge
- Assumed that current level of treatment suitable for ocean outfall
- Rising main of ~4 km required
- Ocean outfall of ~ 3 km required
- Plus upgrade of Treatment Works

Nominal Sea Outfall Route



Mangawhai Community Wastewater Scheme

Sea Outfall

۷SD

Sea Outfall

vsp

Limitations

- Marine Conditions
- Construction location (access to beach)
- Capital Cost
- Cost Uncertainty
- Public Perception
- Maintenance
- Write off of Farm assets
- May need to directional drill pipelines
- Benefits

Future Proof (if sized for future) Option to retain land disposal

Estuary Discharge

****\$D

Estuary Discharge

- Existing disposal field remains available and run at capacity.
- New consent required for discharge
- Short rising main required (~1 km)
- Potentially gravity main
- Due to sensitive nature a high level of treatment required
- Total flow can be diverted to estuary
- Plus upgrade to Treatment Works

Estuary Discharge

wsp

Estuary Discharge Technology

- Higher degree of treatment required
 - Nutrient removal (nitrogen and phosphorus)
 - Suspended solids removal
 - Stringent E.coli limits
- Membrane bioreactor (MBR)
- Small footprint
- Membranes can be selected to achieve low bacterial limits
- Similar to other New Zealand examples
 - Clarks Beach
 - Snells Beach
 - Rotorua WWTP
- Quality as high as BOD < 1, TSS, < 1, NH3, < 1, TN, <3*, TP
- <1, E coli < 1, Viruses 2 log removal
 * TN 3 mg/l is limit of technology.

Estuary Discharge

Technology

- Retrofit existing bioreactor tanks
- Similar Energy requirements
- Require chemicals for periodic cleaning (hypochlorite)
- Pre-packaged plants are available
- Modular membranes- allows for quick expansion
- Due to high mixed liquor suspended solids, existing bioreactor tanks can be used for longer before additional reactor tanks are required.
- Upgrade can be future proofed
- Removal of hypochlorite dosing to effluent
- Considered Best Available Technology



MBR Layout



5000 Connections

7000 Connections



Estuary Discharge

۱۱SD

- Limitations
 - Public Perception of discharge
 - Highest Standard Effluent manageable

Benefits
Most Affordable
Retains land disposal
Best Quality to minimise eco-impact
Allows Next Upgrade on existing Site

Disposal To Harbour and Culture

Culturally,

- Water should return to the land
- To restore the Mauri of the water
- Water is of Papatuanuku and Ranginui and is intrinsic to life and must be able to sustain life and be life sustaining.
- Kaitiakitanga



Proposed Land Contact in Rotorua

Wastewater Treatment Assumptions

Assumptions

All Wastewater is domestic

Off Peak Water contribution 300 l/connection/d Peak Water contribution 600 l/connection/d

Usage includes Infiltration as data is measured

Quality standards are based on experience around NZ for similar applications

Discharge Options

۷SD

Cost Estimates

| Discharge Options | 5000 connections | 7000 connections |
|-------------------|------------------|------------------|
| Disposal Field | \$38m | \$47m |
| Sea Outfall | \$47m | \$56m |
| Estuary | \$26m | \$38m |

All Cost Estimates Exclude cost of Network upgrades

Sea outfall costs are indicative only and subject to pipe route and sea bed conditions, natural dispersion and construction methods.

Wastewater Reuse

۱۱SD

Wastewater Reuse

- Irrigation:
 - Parks
 - Council owned land
 - Resource Consent Required (as WDC)
- Firefighting < 200 m³/yr estimated
- Volume is intermittent due to demand.
- Quality suitable for all areas, if solids are low (class A)
- Note: We recommend use of the Australian Standards for wastewater reuse as no NZ standard.

Current Issues

۷SD

What needs to be done before the upgrade ?

Excess Flow Management at Jack Boyd Drive and Outfall PS

Sand Filter Capacity

Funding

۷SD

Provincial Growth Fund

Shovel Ready

Tourism Infrastructure fund

Other?

Break

15 minutes - call on hold



Project Timeline

۷SD

Preliminary Timeline

Network Studies and Model Community Engagement AEE Consent Application Consent review/hearing Design Tender Period and Award Construction

Total

6 mths 12 mths 18 mths 6 mths 12 mths 9 mths 6 mths 15 mths

84 mths 7 Years

Times may vary depending on solution Some elements may run in parallel

Community Engagement

NSD

Engagement Plan

Is there a Plan?

How does this relate to other engagement?

Programme?

Next Steps

\\\\\])

Agree Next Actions

Close

۱۱SD

Thank you

wsp.com/nz

